



## CERTIFICATION OF CONFORMANCE

**THIS CERTIFIES THAT THE FOLLOWING MATERIAL(S):**

4" - 15" diameter x 14' and 20' lengths SDR-35 & SDR-26 ASTM D3034 PVC gasketed gravity sewer pipe  
18" - 24" diameter x 14' and 20' lengths SDR-35 & SDR-26 ASTM F679 PVC gasketed gravity sewer pipe  
2" - 16" diameter x 20' and 40' lengths SCH-40 ASTM D1785 PVC belled end potable water pipe  
1 ½" - 12" diameter x 20' and 40' lengths SDR-26, SDR-21, & SDR-17 ASTM D2241 PVC gasketed potable water pipe  
4" - 12" diameter x 20' lengths DR-25, DR-18 & DR-14 AWWA C900 PVC gasketed potable water pipe  
14" - 24" diameter x 20' lengths DR-25, DR-21, DR-18 & DR-14 AWWA C900PVC gasketed potable water pipe

**AS MANUFACTURED BY NORTHERN PIPE PRODUCTS:**

**MEETS THE REQUIREMENTS OF THE FOLLOWING SPECIFICATION(S):**

Sewer pipe specifications per the requirements of ASTM D3034 and ASTM F679  
Potable water IPS size pressure pipe specifications per the requirements of ASTM D1785 & ASTM D2241  
Potable water CI-OD size pressure pipe specifications per the requirements of ANSI / AWWA C900  
PVC compound material per the requirements of cell classification 12454 of ASTM D1784

**All pipe certified to be made in the USA as per the requirements of ARRA.**

Date 11/15/2017

**NORTHERN PIPE PRODUCTS INC.**

By   
Derek Hanson

Title VP Engineering